



TEST CERTIFICATE

FOR REPORT MT-08/138-A

CLIENT:

FORCAST WORLDWIDE
UNITS 5 & 6
48 RIVERSIDE ROAD
CHIPPING NORTON NSW 2170

PROP TYPE TESTED:

MUNISH Prop No. 0

APPLICABLE STANDARD:

**AS 3610-1995 FORMWORK FOR CONCRETE
Supplement 2-1996 Appendix A3**

TESTS PERFORMED AT:

Extended length	1.815m	WLL 35kN
Closed length	1.190m	WLL 53kN

DATE OF TESTING:

April 9th 2008


COMMENTS:

Testing of the props as reported in MT-08/138-A confirms that the manufacturers specified WLL of 35kN at 1.190m and 35kN at 1.815m, as marked on prop's identification label, are in compliance with Working Load Limits computed from the test results in accordance with AS 3610-1995.

CONDITIONS:

- 1) Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report.
- 2) This report only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- 3) It remains the responsibility of the client to ensure that the test formwork props and components of the test formwork props as reported herein are representative of the entire production batch.
- 4) This report only covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3.
- 5) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the formwork props as described herein.
- 6) Melbourne Testing Services shall take no responsibility for the installation procedures used for the formwork props described herein.

RODNEY WILKIE
AUTHORISED SIGNATORY



TEST CERTIFICATE

FOR REPORT MT-08/138-B

CLIENT:

FORCAST WORLDWIDE
UNITS 5 & 6
48 RIVERSIDE ROAD
CHIPPING NORTON NSW 2170

PROP TYPE TESTED:

MUNISH Prop No. 1

APPLICABLE STANDARD:

**AS 3610-1995 FORMWORK FOR CONCRETE
Supplement 2-1996 Appendix A3**

TESTS PERFORMED AT:

Extended length	3.115m	WLL 22kN
Closed length	1.860m	WLL 46kN

DATE OF TESTING:

April 9th 2008


COMMENTS:

Testing of the props as reported in MT-08/138-B confirms that the manufacturers specified WLL of 35kN at 1.860m and 18kN at 3.115m, as marked on prop's identification label, are in compliance with Working Load Limits computed from the test results in accordance with AS 3610-1995.

CONDITIONS:

- 1) Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report.
- 2) This report only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- 3) It remains the responsibility of the client to ensure that the test formwork props and components of the test formwork props as reported herein are representative of the entire production batch.
- 4) This report only covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3.
- 5) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the formwork props as described herein.
- 6) Melbourne Testing Services shall take no responsibility for the installation procedures used for the formwork props described herein.

RODNEY WILKIE
AUTHORISED SIGNATORY



TEST CERTIFICATE

FOR REPORT MT-08/138-C

CLIENT:

FORCAST WORLDWIDE
UNITS 5 & 6
48 RIVERSIDE ROAD
CHIPPING NORTON NSW 2170

PROP TYPE TESTED:

MUNISH Prop No. 2

APPLICABLE STANDARD:

**AS 3610-1995 FORMWORK FOR CONCRETE
Supplement 2-1996 Appendix A3**

TESTS PERFORMED AT:

<i>Extended length</i>	<i>3.325m</i>	WLL 18.6kN
<i>Intermediate length</i>	<i>2.684m</i>	WLL 26.8kN
<i>Closed length</i>	<i>2.080m</i>	WLL 49.1kN

DATE OF TESTING:

April 10th 2008

COMMENTS:

Testing of MUNISH Type 2 props, as reported in MT-08/138-C confirms that the manufacturers specified WLL of 35kN at 2.080, 26.8kN at 2.684m and 16kN at 3.330m, as marked on prop's identification label, are in compliance with Working Load Limits computed from the test results in accordance with AS 3610-1995.

CONDITIONS:

- 1) Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report.
- 2) This report only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- 3) It remains the responsibility of the client to ensure that the test formwork props and components of the test formwork props as reported herein are representative of the entire production batch.
- 4) This report only covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3.
- 5) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the formwork props as described herein.
- 6) Melbourne Testing Services shall take no responsibility for the installation procedures used for the formwork props described herein.

RODNEY WILKIE
AUTHORISED SIGNATORY

TEST CERTIFICATE

FOR REPORT MT-07/466

CLIENT:

FORCAST WORLDWIDE
UNITS 5 & 6
48 RIVERSIDE ROAD
CHIPPING NORTON NSW 2170

PROP TYPE TESTED:

MUNISH Prop No. 3

APPLICABLE STANDARD:

***AS 3610-1995 FORMWORK FOR CONCRETE
Supplement 2-1996 Appendix A3***

TESTS PERFORMED AT:

<i>Extended length</i>	<i>3.94m</i>	<i>WLL</i>	<i>11.2kN</i>
<i>Intermediate length</i>	<i>3.32m</i>	<i>WLL</i>	<i>17.2kN</i>
<i>Closed length</i>	<i>2.69m</i>	<i>WLL</i>	<i>33.4kN</i>

DATE OF TESTING:

December 12th 2007

COMMENTS:

Testing of MUNISH Type 3 props, as reported in MT-07/466, confirms that the manufacturers specified WLL of 25kN at 2.69m, 17.2kN at 3.32m and 11.2kN at 3.94m, as marked on the prop's identification label is in compliance with Working Load Limits computed from the test results in accordance with AS 3610-1995.

CONDITIONS:

- 1) Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report.
- 2) This report only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- 3) It remains the responsibility of the client to ensure that the test formwork props and components of the test formwork props as reported herein are representative of the entire production batch.
- 4) This report only covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3.
- 5) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the formwork props as described herein.
- 6) Melbourne Testing Services shall take no responsibility for the installation procedures used for the formwork props described herein.



RODNEY WILKIE
AUTHORISED SIGNATORY

TEST CERTIFICATE

FOR REPORT MT-08/138-D

CLIENT:

FORCAST WORLDWIDE
UNITS 5 & 6
48 RIVERSIDE ROAD
CHIPPING NORTON NSW 2170

PROP TYPE TESTED:

MUNISH Prop No. 4

APPLICABLE STANDARD:

***AS 3610-1995 FORMWORK FOR CONCRETE
Supplement 2-1996 Appendix A3***

TESTS PERFORMED AT:

<i>Extended length</i>	<i>4.860m</i>	<i>WLL</i>	<i>8.3kN</i>
<i>Intermediate length</i>	<i>4.056m</i>	<i>WLL</i>	<i>11.7kN</i>
<i>Closed length</i>	<i>3.353m</i>	<i>WLL</i>	<i>22.1kN</i>

DATE OF TESTING:

April 10th 2008

COMMENTS:

Testing of MUNISH Type 4 props, as reported in MT-08/138-D confirms that the manufacturers specified WLL of 17.5kN at 3.35m, 11.7kN at 4.056m and 8.3kN at 4.86 as marked on the prop's identification label is in compliance with Working Load Limits computed from the test results in accordance with AS 3610-1995.

CONDITIONS:

- 1) Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report.
- 2) This report only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- 3) It remains the responsibility of the client to ensure that the test formwork props and components of the test formwork props as reported herein are representative of the entire production batch.
- 4) This report only covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3.
- 5) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the formwork props as described herein.
- 6) Melbourne Testing Services shall take no responsibility for the installation procedures used for the formwork props described herein.



RODNEY WILKIE
AUTHORISED SIGNATORY